



# CERTIFICATE

No. Z10 06 10 31891 003

**Holder of Certificate:** Murrelektronik GmbH

Falkenstraße 3  
71570 Oppenweiler  
GERMANY

**Factory(ies):** 31891

**Certification Mark:**



**Product:** Safety components  
Digital output module

**Model(s):** MVK-MP K3 DO4(DO4)/DIO4(DIO4)

**Parameters:**

Supply Voltage:	24 ±25% Vdc
Current consumption:	max. 150mA
Operating temperature:	0° C ... +55°C
Storage temperature:	-25..+70°C
IP code :	IP67

**Tested according to:** 98/37/EEC Machinery Directive  
EN 61131-2:2003  
EN 954-1:1996 cat. 3

The listed product was tested on a voluntary basis and complies with the relating standards or directives. The certification mark shown above can be affixed on the product. The certification mark must not be altered in any way. See also notes overleaf.

**Test report no.:** 717500593

**Date,** 2006-10-23

Page 1 of 1

